

Approval Number: 1604500  
Test Report: M106074



Water Regulations Advisory Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

10<sup>th</sup> February 2016

Pipelife Hellas S.A.  
5th KM Old National Road,  
Thiva-Chalkida,  
32 2000 Thiva,  
Greece

**WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**POLYETHYLENE - COMPONENTS.**

**5240**

`Hydrolife-SD`. Black coloured (with blue stripes), extruded HDPE Pipe. For use with water up to 23°C.

**APPROVAL NUMBER: 1604500**  
**APPROVAL HOLDER: PIPELIFE HELLAS S.A.**

The Scheme reserves the right to review approval.  
Approval 1604500 is valid between April 2016 and April 2021

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme