

Our Ref: HL/M110103  
Test Report: M104980

7<sup>th</sup> April 2011

Pipelife Hellas S.A.  
5<sup>th</sup> KM Old National Road,  
Thiva-Chalkida,  
32200 Thiva,  
Greece

**WATER REGULATIONS ADVISORY SCHEME (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**HOSES & TUBING**

**5140**

Hydrolife SD. Black coloured (with blue stripes), extruded high-density polyethylene pipe. For use with water up to 23°C.


**APPROVAL NUMBER: 1103505**  
**APPROVAL HOLDER: PIPELIFE HELLAS S.A.**

The Scheme reserves the right to review approval. This approval is valid between March 2011 and March 2016.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully



Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme